



Addendum #1

Port of Port Arthur

Dock Office Renovation – 2nd Floor

Addendum Date:10-10-2024

A. This Addendum shall be considered part of the RFQ documents for the above-mentioned project as though it had been issued at the same time and shall be incorporated integrally therewith. Where provisions of the following supplementary data differ from those of the original RFQ documents, this Addendum shall govern and take precedence. RESPONDENTS MUST ACKNOWLEDGE THE ADDENDUM ON THEIR SUBMISSION.

B. Respondents are hereby notified that they shall make any necessary adjustments in their estimates as a result of this Addendum. It will be construed that each respondents' submission is with full knowledge of all modifications and supplemental data specified herein.


Addendum No. 1 consists of the following:

- The manufacturer of the door levers is Dormakaba: Reference - C100 Heavy Duty Cylindrical Locksets Catalog
- The door & frame paint color is a custom color match to Roppe base, see next page for Sherwin Williams label.
- This note is to confirm that the Port will be responsible for any adjustments that may be required for the Fire Alarm and/or the Fire Sprinkler system. Contractor is still responsible for protecting existing items in place.
- Insulation will be required above all acoustical ceiling areas, Owens Corning PINK Next Gen minimum R-8 & 24" width unfaced.
- Bathroom wall tile height is 4'6" +/- including Schluter strip and tile base.

Submission Date and Time remains the same

End of Addendum

10-10-24
DATE


Name: Michael Green

SHERWIN-WILLIAMS 707733
409-842-3389

07/09/24
Order# 0371758

INT/EXT
ALL SURFACE
GLOSS

ARCHITECTURAL
OIL BASED
BYHAND

CM NAVY BLUE
CUSTOM MANUAL MATCH

BAC COLORANT	0Z	32	64	128
W1-White	-	17	1	1
B1-Black	2	35	-	-
L1-Blue	6	6	-	-
R3-Magenta	2	42	1	-

ONE GALLON
A11T00204

ULTRADEEP
640325767

TRIM

NOT RECOMMENDED FOR USE ON VINYL

Non Returnable Tinted Color

CAUTION: To assure consistent color, always order enough paint to complete the job and intermix all containers of the same color before application. Mixed colors may vary slightly from color strip or color chip.



0371758-001